

Water Operator Report

City of Rubaville

June 1, 2022

1. Last month's data:

- **Gallons of water produced:** 4.5 million gallons
- **Gallons of water backwashed:** 1.2 million gallons
- **Gallons of wastewater discharged:** 3.9 million gallons
- **Test results:** All test results ok except TTHM&HAA5 lab results indicate levels below the MCL.
- **Preventative Maintenance Plan report:** Daily, weekly, and monthly tasks completed as required, and the completed PMP report was emailed to the RMW this morning.

2. Notes about the month:

- Soda Ash machine has been installed and is up and running.
- RMW visited to help install the machine. Also went over some training and maintenance matters.

3. Concerns moving forward:

- Sanitary Survey is required by ADEC within the next two months.
- Low on polymer, but supply chains have been slow. Working with the bookkeeper to get that ordered urgently.
- We still need three new submersible pumps for the Main Street line. Please consider amending the budget to cover these in FY23.

Attested:

Dennis the Menace

Date