

Shungnak Activity Report

Community Overview

Lead RUBA Staff: Margaret Hansen, Kotzebue Office

2003 Population: 264

Region: Northwest Arctic

Local Governments: 2nd Class City,
Tribal Council



The City of Shungnak operates the piped water and sewer system. The City Council is the policy making board for the utility. The water infiltration gallery was destroyed by ice several years ago, and needs replacement. A reservoir is intermittently filled from the Kobuk River. A portable pump fills a 200,000-gallon steel storage tank through 1,110' of buried arctic pipe. Groundwater wells have proven unsuccessful. Piped water and sewer are provided to 53 homes (those at the top of the bluff), clinic, school, and community building. Shungnak has a six-inch buried gravity sewage main, which drains into a small diked lake one-half mile northwest of the city. The main, lift station, and manholes need replacement. The effluent is chlorinated before discharge. A new landfill has recently been completed.

RUBA Activity This Quarter

Kotzebue RUBA staff provided on site training and assistance to the administrator on capital matching grants and reports. Shungnak called for assistance and reported having cash flow problems. She also need to complete her business plan for the VSW project happening this summer. I provided training and assistance in completing her FY 05 VSW questionnaire.

Capacity Indicators

Finances

Essential Indicators

- | Yes | No | |
|-------------------------------------|--------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | All revenue and expenses for the utility are listed in the utility budget. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adopted a balanced realistic budget. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Monthly financial reports are prepared and submitted to the policy making body. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility is receiving revenues (user fees or other sources) sufficient to cover operating expenses. |

Sustainable Indicators

- | | | |
|-------------------------------------|-------------------------------------|---|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | The utility is receiving revenues (user fees or other sources) sufficient to cover operating expenses and Repair & Replacement (R&R) costs. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | YTD revenues are at a level equal to or above those budgeted. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | YTD expenditures are at a level equal to or below those budgeted. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | A monthly manager's report is prepared. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Budget amendments are completed and adopted as necessary. |

Finances Comments:

The council will increase their water/sewer fees in January from \$80 to \$100 on October 1, 2004.

Accounting Systems

Essential Indicators

- | Yes | No | |
|-------------------------------------|--------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adopted a collection policy and actively follows it. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility bills customers on a regular basis. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | An accounts receivable system is in place which track customers and reports past due accounts and amounts. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | An accounts payable system is in place. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The payroll system correctly calculates payroll and keeps records |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | A cash receipt system is in place that records incoming money and what it was for. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The Utility has a cash disbursement system that records how money was spent. |

Sustainable Indicators

- | | | |
|-------------------------------------|--------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | A chart of accounts is used that identifies categories in a reasonable, usable manner. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | Monthly bank reconciliations have been completed for all utility accounts. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has a purchasing system that requires approval prior to purchase, and the approval process compares proposed purchases to budgeted amounts. |

Accounting Comments:

The Administrator is doing very well with all accounting requirements.

Tax Problems

Essential Indicators

- | Yes | No | NA | |
|-------------------------------------|--------------------------|-------------------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | The utility has a system to accurately calculate, track, and report payroll tax liabilities. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | The utility is current on filing tax reports. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | The utility is current on making tax deposits. |
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | If there are any past tax liabilities, a repayment agreement has been signed and repayments are current. |

Tax Problems Comments:

The city is paying and reporting timely.

Personnel System

Essential Indicators

- | Yes | No | |
|-------------------------------------|--------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has a posted workers compensation insurance policy in effect. |

Sustainable Indicators

- | | | |
|-------------------------------------|--------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adopted and uses a Personnel Policy, which has been reviewed by an attorney, AML, or DCED for topics and language. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adequate written job descriptions for all positions. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adopted and follows a written personnel evaluation process that ties the job description to the evaluation. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has an adequate written hiring process. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has personnel folders on every employee that contain at least: I-9, Job Application and Letter of Acceptance. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has a probationary period for new hires that includes orientation, job-training/oversight, and evaluations. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility provides training opportunities to staff as needed and available. |

Personnel System Comments:

None

Organizational Management

Essential Indicators

- | Yes | No | |
|-------------------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The entity that owns the utility is known and the entity that will operate the utility is set. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The policy making body is active in policy making of the utility. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The policy making body enforces utility policy. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has an adequately trained manager. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has an adequately trained bookkeeper. |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | The utility has an adequately trained operator(s). |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adopted the necessary ordinances (or rules and regulations) necessary to give it the authority to operate. |

Sustainable Indicators

- | | | |
|-------------------------------------|--------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility has adopted an organizational chart that reflects the current structure. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The policy making body meets as required. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | The utility complies with the open meeting act for all meetings. |

Organizational Management Comments:

The city has had the same operator for some years now but he cannot pass any operator training test. He does know the system and can do his job but continues to have a problem getting certified. The city will send alternates to the next training session.

Operation of Utility**Essential Indicators**

Yes	No	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The utility operator(s) are actively working towards necessary certification.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	The utility has a preventative maintenance plan developed for the existing sanitation facilities.

Sustainable Indicators

<input checked="" type="checkbox"/>	<input type="checkbox"/>	The manager receives a monthly O&M report from the utility operator and routinely “spot checks” the facilities to see that the maintenance items are being completed.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	The utility has a safety manual and holds safety meetings.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Utility facilities have not suffered any major problems/outages due to management issues that are still unresolved.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The utility is operating at the level of service that was proposed.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The operator provides status reports to the manager on a routine basis.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The utility has completed and distributed its <u>Community Confidence Report (CCR)</u> .
<input type="checkbox"/>	<input checked="" type="checkbox"/>	The utility is not on the <u>Significant Non-Compliance (SNC)</u> list.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The utility maintains an inventory control list.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	The utility maintains a critical spare parts list.

Operation of Utility Comments:

The administrator has met with the operators about the need to become certified. She will be posting a notice to get a second alternate in hopes that one of the three will pass. She has sent out her community confidence reports last quarter.

RUBA Activities For The Coming Quarter

The Kotzebue LGS continues to work with the administrator to complete a rate study to determine if a utility rate change is necessary above the \$100 rate.