THE STATE of ALASKA
GOVERNOR BILL WALKER

Department of Public Safety
DIVISION OF FIRE AND LIFE SAFETY
Plan Review Bureau - Anchorage
5700 East Tudor Road
Anchorage, Alaska 99507-1225
Main: 907.269.2004
Fax: 907.269.0098

December 08, 2016

J Grant
One Hit Wonder
PO Box 321
Ester, AK 99725

SUBJECT:	Parks Highway Chevron (One Hit Wonder) - Ester - Renovation / Remodel
TENANT:	One Hit Wonder
CITY:	Ester
PLAN REVIEW:	2016Anch1745
OCCUPANCY:	M

2009 INTERNATIONAL BUILDING AND FIRE CODE

Dear J Grant:

Plans for the subject facility Renovation / Remodel have been reviewed by this office for conformity with the State Fire and Life Safety Regulations. However, before construction, alteration, or repairs may begin, the list of item(s) on the following page(s) require clarification and/or new drawings must be submitted for approval.

Please provide the above information to our office within thirty (30) days from the date of this letter.

If you have any questions on this matter, please contact us at the address above.

Sincerely,

Jillian Roberts
Plans Examiner

RECEIVED
FEB 09 2017

Reference is made to the above cited plan review, specifically to item(s):

1. Provide a completed unreviewed existing building checklist and a detailed floor plan of the entire building showing the use of each space OR provide the original plan review number.

2. Indicate the location and classification of the fire extinguisher.' One 2-A fire extinguisher per 6000 sq. ft. in light hazard (offices) and one 2-A per 3000 sq. ft. in an ordinary hazard and 4-A per4000 sq. ft. inextra high hazard. Maximum travel distance to a fire extinguisher is 75 feet.
   IFC. 906.3(1)

RECEIVED
FEB 09 2017
ALCOHOL MARIJUANA CONTROL OFFICE
STATE OF ALASKA