Lance Wells

From: Daniel Clift <dan@determinedesign.com>
Sent: Friday, July 21, 2017 4:54 PM
To: Wright, Dixie D.; 'cannabaska@gmail.com'; Lance Wells
Subject: Re: address update on plan review approval to 217 4th Ave

Thank you Dixie!!,

Lance, see forwarded email that DHHS has updated its Plan Review to reflect the new address. When the retail is open, the permit will be attached to this address.

Daniel H. Clift
DETERMINE DESIGN LLC
903 W Northern Lights Blvd, Ste 206
Anchorage, Alaska 99503
To view our work and keep in touch visit our website-
determinedesign.com
Work: (907)339-9100

D.E.C/ DHHS APPROVAL

From: Wright, Dixie D. <WrightDD@ci.anchorage.ak.us>
Sent: Friday, July 21, 2017 4:50:15 PM
To: Daniel Clift; 'cannabaska@gmail.com'
Subject: RE: address update on plan review approval to 217 4th Ave

Good afternoon Daniel & Smadar:

The marijuana retail plans review submitted to DHHS Environmental Health for **Alaskasense LLC [SR 343]**, 217 E 4th Ave, are hereby **approved**

for those items with which the Department of Health and Human Services is concerned. This approval is limited to eighteen months from the original date of approval on 12/14/16. If an extension is needed, please send a written request to this office. If no action has been taken by the applicant, new plans will need to be submitted along with the appropriate fees.

Items such as your hand washing and 3 compartment sink, lighting (minimum 50 foot-candles in consumable handling and ware-washing areas, and 20 foot-candles in other areas) and surface finishes (non-absorbent,

durable, smooth & easily cleanable) will be field checked during the opening inspection. Please ensure that your returnable/recalled items are stored in an area clearly marked and away from current products.

Seams and joints between counters and walls must be sealed. Verify all equipment meets ANSI/NSF or equivalent standards.

This approval is subject to provisions of Chapter 16.60 AMC and is based upon the plans and comments submitted. Please call concerning any changes or questions. **A Health Permit and opening inspection from**

DHHS is required for opening.

Contact this office:

- if you plan any changes to the facility;
- to schedule construction inspections; and

Received by AMCO 3/15/18

- to schedule an opening inspection prior to bringing in marijuana retail items.

Ensure that all permits required by Development Services, such as connections to electrical service or change of use permits, have been applied for and approved prior

to the issuance of a Health Permit.

Next steps:

1. **Apply for your health permit at DHHS Environmental Health, 3rd Floor at least 7 days prior to wanting to open. (fees are prorated quarterly from opening date)**
2. **Schedule your first of two inspections required to open.**

Dixie D Wright
Environmental Health Specialist
Municipality of Anchorage
Dept, of Health and Human Services
825 L St Suite 300
Mail: P.O. Box 19665
Anchorage, AK 99519-6650
PH# (907)343-4081
FAX (907)249-7693
WrightDD@muni.org

From: Daniel Clift [mailto:dan@determinedesign.com]
Sent: Friday, July 21, 2017 2:11 PM
To: Wright, Dixie D. <WrightDD@ci.anchorage.ak.us>; Smadar Warden <cannabaska@gmail.com>
Subject: 217 4th ave

Dixie, do we have everything in order for the 217 4th ave address stating that the DHHS application is approved for this location?

Daniel H. Clift
DETERMINE DESIGN LLC
903 W Northern Lights Blvd, Ste 206
Anchorage, Alaska 99503
To view our work and keep in touch visit our website-
determinedesign.com
Work: (907)339-9100

Received by AMCO 3/15/18